



中国国家强制性产品认证证书



证书编号: 2020322310001312

认证委托人名称: 施耐德电气(中国)有限公司上海分公司

认证委托人地址: 上海市普陀区绥德路 669 号

生产者名称: 施耐德电气日本股份有限公司

生产者地址: 4-4-9 Kitahama, Chou-Ku, OSAKA-SHI

生产企业名称: 无锡普洛菲斯电子有限公司

生产企业地址: 江苏省无锡市汉江路 20 号

产品名称: 人机界面 - 图形终端

系列、规格、型号: PFXSP 系列、PFXFP 系列、PFXZC 系列

标准: GB 3836.1-2010、GB 3836.8-2014、GB 12476.1-2013、
GB 12476.5-2013

上述产品符合强制性产品认证实施规则 CNCA-C23-01:2019 的要求, 特发此证。

发证日期: 2020 年 10 月 23 日 有效期至: 2025 年 9 月 14 日

首次发证日期: 2020 年 9 月 15 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



批准:



上海仪器仪表自控系统检验测试所有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



CERTIFICATE NO: 2020322310001312

APPLICANT: Schneider Electric (China) Co. Ltd. Shanghai Branch
ADDRESS: No.669 SuiDe Road,Putuo District,Shanghai,China
MANUFACTURER: Schneider Electric Japan Holdings
ADDRESS: 4-4-9 Kitahama, Chou-Ku, OSAKA-SHI
FACTORY: WuXi Pro-Face Co. Ltd.
ADDRESS: No.20 HanJiang Road, WuXi, JiangSu, China

PRODUCTNAME: Human Machine Interface - Graphic Terminal
SERIES,SPECIFICATION,MODEL: PFXSP series, PFXFP series, PFXZC series
STANDARDS: GB 3836.1-2010、 GB 3836.8-2014、 GB 12476.1-2013、
 GB 12476.5-2013

This is to certify that the above mentioned product(s)complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).

Valid from:October 23, 2020

Valid until: September 14, 2025

Date of original certification:September 15, 2020

The validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate is available through CNCA's website: www.cnca.gov.cn



APPROVAL:

Xu JianPing



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.

<http://www.sitilas.com.cn>

Building 9,103 Cao Bao Road, Shanghai 200233,China

Tel: +86 21 64510844

S 0001971



中国国家强制性产品认证证书



证书编号：2020322310001312

附件

产品名称： 人机界面 - 图形终端

型号规格： PFXSPa

a 可为：5500TPD、5600TPD、5600TPDLC、5660TPD、5700TPD、5400WAD、5500WAD、5600WAD、5700WCD、5800WCD、5B10、5B10LC、5B40、5B41、5B41LC。

PFXFPb

b 可为：5600TPD、5700TPD。

PFXZCc

c 可为：DADEXP1、DADEXR1、DEUPF1、DEUCA1、HEUFN1、HEUCAM1。

注：型号可后缀其他代码，不影响产品防爆性能

防爆标志： Ex nA nC II C T4/T6 Gc 适用于除PFXSP5700WCD和PFXSP5800WCD外所有型号；
Ex nA II C T4 Gc 仅适用于PFXSP5700WCD和PFXSP5800WCD；
Ex tD A22 IP6X T85°C/T135°C 适用于所有型号。

电气参数： PFXSP系列：U_n=12 / 24 VDC
PFXFP系列：U_n=12 / 24 VDC
PFXZCD系列：U_n=3.3 / 12 / 24 VDC

批 准：



上海仪器仪表自控系统检验测试所有限公司