



TYPE APPROVAL CERTIFICATE

Certificate No:
TAA00000CD
Revision No:
1

This is to certify:

That the Peripheral Equipment

with type designation(s)
Touch Screen graphic terminals

Issued to
Schneider Electric Japan Holdings Ltd.
Osaka, Japan

is found to comply with
DNV GL rules for classification – Ships, offshore units, and high speed and light craft

Application :

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV.

Location classes: See page 2 & 3.

Issued at **Høvik** on **2021-05-19**

for **DNV**

This Certificate is valid until **2025-06-30**.

DNV local station: **Kobe**

Approval Engineer: **Nils Jarem**

.....
Marta Alonso Pontes
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Product description

Pro-Face Graphic Operator Interfaces as listed below:

Pro-face Reference	Temperature Class	Humidity Class	Vibration Class	EMC Class	Enclosure Class	Notes
GP4105G1D	B	B	A	B*	B	IP65 (front panel only)
GP4105W1D						
GP4106G1D						
GP4106W1D						
GP4107G1D						
GP4107W1D						
PFXGM4201TAD	B	B	A	B*	B	IP65 (front panel only)
PFXGM4301TAD						
PFXXM4200TP						
PFXXM4300TP						
PFXGM4B01D						
PFXLM4301TADAC	B	B	A	B*	B	IP65 (front panel only)
PFXLM4301TADAK						
PFXLM4301TADDC						
PFXLM4301TADDK						
PFXLM4201TADAC						
PFXLM4201TADAK						
PFXLM4201TADDC						
PFXLM4201TADDK						
PFXLM4B01DAC						
PFXLM4B01DAK						
PFXLM4B01DDC						
PFXLM4B01DDK						
PFXZXMADSM31						
PFXZXMADSM51						
ST401-AG41-24V						
ST403-AG41-24V						
AGP3300-T1-D24	A	A	A	A*	B	IP65 (front panel only)
AGP3400-T1-D24						
AGP3450-T1-D24						
AGP3500-T1-D24						
AGP3550-T1-D24						
AGP3600-T1-D24						
AGP3650-T1-D24						
AGP3750-T1-D24						

* To comply with EMC requirements, see application/limitation

Target Product list

Commercial Reference		Description
Pro-face Brand	Schneider Brand	
PFXSTM6200WAD	HMISTM6200	Rear & 4" Display Module
PFXSTM6400WAD	HMISTM6400	Rear & 7" Display Module
PFXSTM6B	HMISTM6B	Rear Module
PFXSTM62TP	HMISTM62	4" Display Module
PFXSTM64TP	HMISTM64	7" Display Module
PFXZCM6SM3	HMIZM6RDP3	Cable 3m
PFXZCM6SM5	HMIZM6RDP5	Cable 5m
PFXZCM6SM10	HMIZM6RDP10	Cable 10m
PFXZCM6DSA	HMIZM6DSA	DIN rail adapter
PFXSTM6B00D	HMISTM6BOX	Rear Module & DIN rail adapter

Commercial Reference		Location classes				
Pro-face Brand	Schneider Brand	Temperature	Humidity	Vibration	EMC	Enclosure
PFXSTM6200WAD	HMISTM6200	B	B	A	B	B/IP65 (front Panel only)
PFXSTM6400WAD	HMISTM6400					
PFXSTM6B	HMISTM6B					
PFXSTM62TP	HMISTM62					
PFXSTM64TP	HMISTM64					
PFXZCM6SM3	HMIZM6RDP3					
PFXZCM6SM5	HMIZM6RDP5					
PFXZCM6SM10	HMIZM6RDP10					
PFXZCM6DSA	HMIZM6DSA					
PFXSTM6B00D	HMISTM6BOX					

Place of manufacture

Wuxi Pro-face Electronics Ltd.
 No.20 Hanjiang Road
 National Hi-tech Industrial Development Zone
 Wuxi, Jiangsu 214028
 P.R. CHINA

PT Schneider Electric Manufacturing Batam
 Batamindo Industrial Park, Block 4&208,
 Muka Kuning,
 Batam Island, 29433,
 Indonesia

Approval conditions

The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNV, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case. Reference is made to DNV GL rules for classification of ships Pt.4 Ch.9 Control and monitoring systems.

Application/Limitation

Products have been tested up to 20% nominal voltage variation as for equipment not connected to the battery during charging.

To cover EMC class A and B requirements for devices marked with * above, installation requirements according to Certification Note, doc. No.:10DD-4GD00017, must be followed.

For installation on bridge, the equipment to be installed not less than 5m away from magnetic compass as required in 11.2 of IEC60945.

EMC in the range 2 GHz to 6 GHz according to DNVGL-CG-0339, December 2019 has not been documented. EMC up to 6 GHz must additionally be documented for installation on ships contracted for construction on or after 2022-01-01.

Type Approval documentation

Pro-face Reference	Manuals incl. drawings	Test report No.
GP4105G1D	GP-4100 Series	10C00025RPT01 dated 2010-07-30
GP4105W1D	Hardware Manual	10C00026RPT02 dated 2010-07-15
GP4106G1D	File:	HBR-RL-10.123 dated 2010-07-14
GP4106W1D	GP4100-MM01-ENG-PDFo	CJ09-090361S dated 2009-11-18
GP4107G1D		
GP4107W1D		
PFXGM4201TAD	GP-4201TM/GP4301TM/	0908M01V dated 2009-11-08
PFXGM4301TAD	4000M Hardware Manual	1004M01V dated 2010-04-28
PFXXM4200TP	File:	A09-065-WT dated 2010-02-12
PFXXM4300TP	GP42_43TM-MM01-ENG-PDFh	A10-035-WT dated 2010-10-18
PFXGM4B01D		CJ11-104232S dated 2011-08-1
		CJ11-104232S2 dated 2011-05-24
PFXLM4301TADAC	LT-4201TM/4301TM	201214-042 dated 2013-03-11
PFXLM4301TADAK	Hardware Manual	201214-063 dated 2014-05-29
PFXLM4301TADDC	File:	201214-073 dated 2014-05-29
PFXLM4301TADDK	lt4000m_i	201214-083 dated 2014-05-29
PFXLM4201TADAC		201214-443 dated 2014-06-04
PFXLM4201TADAK		ET2014-5-619 dated 2014-06-06
PFXLM4201TADDC		
PFXLM4201TADDK		
PFXLM4B01DAC		

Pro-face Reference	Manuals incl. drawings	Test report No.
PFXLM4B01DAK		
PFXLM4B01DDC		
PFXLM4B01DDK		
PFXZXMADSM31		
PFXZXMADSM51		
ST401-AG41-24V	ST Series User Manual	0510S01C dated 2005-12-31,
ST403-AG41-24V	File:	0510S01V dated 2005-09-29
AGP3300-T1-D24	ST40X-MM01-ENGf	0510S02C dated 2005-12-31
AGP3400-T1-D24		0510S02V dated 2005-09-29
AGP3450-T1-D24	GP3000 Series	0510S03C dated 2006-08-14
AGP3500-T1-D24	Hardware Manual	0510S04V dated 2005-12-31
AGP3550-T1-D24	File:	0510S05V dated 2006-02-21
AGP3600-T1-D24	GP3000-MM01-ENG-PDFab	0510S06V dated 2006-02-21
AGP3650-T1-D24		0510S07V dated 2005-12-12
AGP3750-T1-D24		0510S08V dated 2005-11-30
		0510S09V dated 2005-12-31
		0510S10V dated 2005-12-12
		0510S11V dated 2005-12-31
		0510S12V dated 2006-08-02
		0510S14V dated 2006-08-02
		0510S15V dated 2006-08-02
		0510S16V dated 2006-08-02
		0510S17V dated 2006-10-31
		0510S18E dated 2006-11-03
		2006-0134-01A dated 2006-08-24
		2006-0134-02A dated 2006-08-24
		2006-0134-03A dated 2006-08-24
		2006-0134-04A dated 2006-08-24
		2006-0134-05 dated 2006-11-10
		2006-0134-06 dated 2006-11-10
		2006-0134-07 dated 2006-11-10
		2006-0134-08 dated 2006-11-10
		2006-0412-00 dated 2006-07-25
		2006-0412-01 dated 2006-07-25
		2006-0412-02 dated 2006-07-25
		2006-0412-03 dated 2006-07-25
		2006-0412-04 dated 2006-07-25
		2006-0412-05 dated 2006-07-25
		200604-3056C-R1-E dated 2006-07-10
		200604-3056C-R2-E dated 2006-07-10
		200604-3056C-R3-E dated 2006-07-10
		200604-3056C-R4-E dated 2006-07-10
		R0510281C1-E dated 2005-12-19
		R0510281C2-E dated 2005-12-19
PFXSTM6200WAD		
PFXSTM6400WAD	Harmony STM6 User Manual,	
PFXSTM6B	EIO0000004129_00,	
PFXSTM62TP	dated 2020-08	
PFXSTM64TP		IOCC-LAB-TF-002
PFXZCM6SM3	STM6000 Series Hardware	Contained in DNV doc. no: 99, page 8.
PFXZCM6SM5	Manual (Pro-Face),	(Product Synthesis)
PFXZCM6SM10	STM6000-MM01-EN_00,	
PFXZCM6DSA	dated 2020-08	
PFXSTM6B00D		
Certification note, doc. No.: 10DD-4GD00017 dated 2012-08-20		

Type approval renewal assessment report for TAA00000CD, Batam, Indonesia 2021-04-19
 Type approval renewal assessment report for TAA00000CD, Wuxi, China 2021-05-13

Tests carried out

Applicable tests according to class guideline DNVGL-CG-0339, December 2016.



Job Id: **262.1-009048-4**
Certificate No: **TAA00000CD**
Revision No: **1**

Marking of product

The products to be marked with:

- manufacturer name
- model name
- serial number
- power supply ratings

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE