



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2012010305552772

## NAME AND ADDRESS OF THE APPLICANT

Schneider Electric Manufacturing (Wuhan) Co., Ltd.  
No.1 3rd Fozuling Road, Donghu New&High Tech Development Zone, Wuhan,  
P. R. China

## NAME AND ADDRESS OF THE MANUFACTURER

P T Schneider Electric MFG Batam  
Batam Industrial park - BLK 4 - Mukakuning - Batam - Indonesia

## NAME AND ADDRESS OF THE FACTORY

P T Schneider Electric MFG Batam  
Batam Industrial park - BLK 4 - Mukakuning - Batam - Indonesia

## NAME, MODEL AND SPECIFICATION

Limit Switch

XCKMR, XCKVR;Ui=AC500V;Ith=10A;AC-15:Ue=AC240V, Ie=3A;DC-  
13:Ue=DC125V, Ie=0.55A;IP66(for XCKMR), IP65(for XCKVR)

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.5-2008

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-C03-02:2014).

Date of issue: May.31, 2016      Date of expiry: Jul.04, 2017

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: Jul.04, 2012

This certificate can be verified through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



President:

Wang Kejiao



**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

Q 1425059



# 中国国家强制性产品认证证书

证书编号: 2012010305552772

## 委托人名称、地址

施耐德电气制造(武汉)有限公司  
武汉东湖新技术开发区佛祖岭三路一号

## 生产者(制造商)名称、地址

P T Schneider Electric MFG Batam  
Batam Industrial park - BLK 4 - Mukakuning - Batam - Indonesia

## 生产企业名称、地址

P T Schneider Electric MFG Batam  
Batam Industrial park - BLK 4 - Mukakuning - Batam - Indonesia

## 产品名称和系列、规格、型号

### 限位开关

XCKMR, XCKVR (型号解释详见附件);  $U_i=AC500V$ ;  $I_{th}=10A$ ;  $AC-15:U_e=AC240V, I_e=3A$ ;  $DC-13:U_e=DC125V, I_e=0.55A$ ;  $IP66$  (for XCKMR),  $IP65$  (for XCKVR)

## 产品标准和技术要求

GB 14048.5-2008

上述产品符合强制性产品认证实施规则  
CNCA-C03-02:2014的要求, 特发此证。

发证日期: 2016年05月31日

有效期至: 2017年07月04日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2012年07月04日

本证书的相关信息可通过国家认监委网站 [www.cnca.gov.cn](http://www.cnca.gov.cn) 查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>



Q 1425059



# 中国国家强制性产品认证证书

附录:

第 1 页 共 2 页

证书编号: 2012010305552772

纸号: 1425059

型号的解释:

<u>XCKMR</u>	<u>5</u>	<u>4</u>	<u>D</u>	<u>1</u>	<u>H29</u>
I	II	III	IV	V	VI

I 产品基本型号

XCKMR: 成品, 金属型限位开关, 3 个电缆进线孔, 2 个触头模块  
 XCKVR: 成品, 塑料型限位开关, 3 个电缆进线孔, 2 个触头模块

II

触头类型和触头动作状态

2-2 个(INC+INO) 触头模块, 慢断, 2 个动作状态  
 4-2 个(INC+INO) 触头模块, 慢断, 4 个动作状态  
 5-2 个(INC+INC) 触头模块, 慢断, 5 个动作状态

III

机械位置

4-4 个位置.

IV

操作类型

D- 没有停止状态  
 SR- 对称状态

V

操作头位置

1- 前位  
 2- 后位

注: 此附录与证书同时使用时有效。



主任:

## 中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





# 中国国家强制性产品认证证书

附录:

第 2 页 共 2 页

证书编号: 2012010305552772

纸号: 1425059

## VI 进线孔

空白-3 个螺纹孔适用于欧洲电缆密封管型号 13  
H7 - 1/2 in. NPT 螺纹孔或提供 1/2 in. NPT 改编器  
H29 - ISO M20 螺孔

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

