



Certificate of Compliance

Certificate: 2565371

Master Contract: 240515

Project: 2565371

Date Issued: October 12, 2012

Issued to: Telemecanique/Schneider Electric

Industries SAS
Zone Industrielle No. 3
L'Isle d'Espagnac, 16340
France
Attention: Mr. Christophe Delaitre

The products listed below are eligible to bear the CSA Mark shown



J.-C. Chow

Issued by: J.-C. Chow

PRODUCTS

CLASS 3211 03 - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Auxiliary Devices

Limit switches, Cat. No. XCKVR, followed by two-digit number followed by D or SR followed by 1 or 2 followed by a H29 or H7; rating codes A300, Q300; special purpose enclosure Type 4X Indoor use or 12K.

Notes:

1. The limit switches without NPT conduit entry may be marked with special purpose enclosure rating when provided with instructions in package indicating the kit of NPT-Metric adaptors necessary to maintain the effectiveness of the special purpose rating and the NPT conduit entry.
2. These limit switches are certified as end-of-line auxiliary devices, where only one conduit is to be connected to the enclosure.

APPLICABLE REQUIREMENTS

CSA-C22.2 No. 14-10 - Industrial Control Equipment

CAN/CSA-C22.2 No. 94-M91 - Special Purpose Enclosures