

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20150707-E361380  
**Report Reference** E361380-20141107  
**Issue Date** 2015-JULY-07

**Issued to:** SCHNEIDER ELECTRIC AUTOMATION GMBH  
SCHNEIDERPLATZ 1  
97828 MARKTHEIDENFELD GERMANY

**This is to certify that  
representative samples of**

PROGRAMMABLE CONTROLLERS FOR USE IN  
HAZARDOUS LOCATIONS

Programmable Controllers for use in Hazardous Locations,  
Class I, Division 2 Groups A, B, C and D. TM241CE24T  
TM241CEC24T TM241C24T TM241C40T TM241CE40T  
TM241CE24U TM241CEC24U TM241C24U TM241C40U  
TM241CE40U ,TM241CE24R TM241CEC24R TM241C24R  
TM241C40R TM241CE40R

Listed Accessories, A/D Card, Model TMC4AI2, TMC4TI2,  
TMC4HOIS01, TMC4PACK01

Listed Accessory, D/A Card, Model TMC4AQ2

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:**

Standard No. ANSI/ISA 12.12.01, Nonincendive Electrical  
Equipment for Use in Class I and II, Division 2 and Class III,  
Divisions 1 and 2 Hazardous (Classified) Locations,  
Standard No. CAN/CSA C22.2 No. 213-M1987, Non-  
incendive Electrical Equipment for Use in Class I, Division 2  
Hazardous Locations

**Additional Information:**

See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's  
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

