CERTIFICATE OF COMPLIANCE

Certificate Number Report Reference Issue Date

20150707-E361380 E361380-20150627 2015-JULY-07

Issued to: SCHNEIDER ELECTRIC AUTOMATION GMBH SCHNEIDERPLATZ 1 97828 MARKTHEIDENFELD GERMANY

This is to certify that representative samples of

that PROGRAMMABLE CONTROLLERS FOR USE IN s of HAZARDOUS LOCATIONS

TM251 Series, Programmable Controllers, for use in Class I, Division 2 Groups A, B, C and D, Hazardous Locations. TM251MESE, TM251MESC

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety:Standard No. ANSI/ISA 12.12.01, Nonincendive Electrical
Equipment for Use in Class I and II, Division 2 and Class III,
Divisions 1 and 2 Hazardous (Classified) Locations,
Standard No. CAN/CSA C22.2 No. 213-M1987, Non-
incendive Electrical Equipment for Use in Class I, Division 2
Hazardous LocationsAdditional Information:See the UL Online Certifications Directory at

www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.

Bruce Mahrenholz, Director North American Certification Program



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at http://ul.com/aboutul/locations/