



# OPERATOR INTERFACE PRODUCTS APPLICATION NOTE

Subject: 2000 or 3000 Softscreen to AB SLC500 PLC via 1747-AIC

AN# 1005B

Date: 7/16/96

Name: Christopher J. Biernacki

Page: 1 of 1

Description: Options for connectivity...

This diagram shows the two methods a 2000 or 3000 Softscreen terminal can be incorporated onto a SLC500 DH485 network using an AB 1747-AIC module. The Xycom can connect through a 1747-PIC module into the J1 port or be wired daisy-chain directly onto the DH485 link.

The method of connection must be reflected in the Softscreen Port Configuration.

