



# OPERATOR INTERFACE PRODUCTS APPLICATION NOTE

Subject: 2000 and 3000 Softscreen with a SLC5/04 on a DH485 network AN# 1009B

Date: 7/16/96

Name: Chris Biernacki

Page: 1 of 1

Description: Options for connectivity...

As stated in the Allen Bradley SLC 500 Modular Hardware Style Installation and Operation Manual, the SLC5/04 can be connected to a DH485 network through Channel Zero, a 1747-PIC module, and a 1747-AIC module. Channel Zero on the SLC5/04 must be set as DH485 Master and be connected to the J1 Peripheral connection on a 1747-AIC module through the 1747-PIC module. From here, the 1747-AIC module can be connected to a DH485 network and communicate with others devices that are also capable of linking to the network.

A Softscreen terminal can be connected to this DH485 network and have complete access to the devices on the network, as covered in Xycom Application Note 1005.

