

**DECLARATION OF CONFORMITY**  
**in accordance with EN 45014:1989**

**Manufacturers Name:** Xycom Automation Inc.

**Manufacturers Address:** 750 North Maple Road  
Saline, MI 48176  
USA.

**Declares under our sole responsibility that the product:**

Product name: Operator Interface Workstation

Model Number: 3412XXX

Product Options: This declaration covers all options of the above product which bear the CE Marking.

**Is in conformity with the following standards or other normative documents:**

Low-Voltage Directive 73/23/EEC: EN 60950:1992 with Amendments 1, 2, 3, and 4 and with National Deviations.

EMC Directive 89/336/EEC: EN 55022:1994, Class A ITE EMI  
EN 50082-2:1995, Generic industrial immunity

- EN 61000-4-2:1995 Electrostatic discharge
- EN 61000-4-3:1996 Radiated RF EM field
- EN 61000-4-4:1995 Electrical fast transient burst
- EN 61000-4-6:1997 Conducted RF disturbance
- EN 61000-4-8:1993 Power frequency magnetic field

**Supplementary Information:**

The product herewith complies with the requirements of the Low Voltage Directive 73/23/EEC (and amending directive 93/68/EEC), and the EMC Directive 89/336/EEC (and amending directives 91/263/EEC, 92/31/EEC, 93/68/EEC).

The XYCOM model 3412XXX operator interface workstation was tested for EMC compliance as a model 3412KPT with the Touch Screen option installed and as an apparatus within a system as described in the relevant EMC test files.

Saline, Michigan, USA.

5-April-00



**Location**

**Issue**

**Timothy E. Wallaert**

**Date**

**Vice President, Engineering**

**European Contact:**

Xycom Europe Ltd., 21 Tenter Road, Moulton Park, Northampton, NN3 6AX England  
+44-1604-790-767 (FAX +44-1604-790-722)