

**DECLARATION OF CONFORMITY**  
in accordance with EN 45014:1989

**Manufacturers Name:** Xycom Automation Inc.

**Manufacturers Address:** 750 North Maple Road  
Saline, MI 48176  
USA.

**Declares under our sole responsibility that the product:**

**Product name:** Operator Interface Workstation

**Model Number:** 3515XXXX, where X is any alphanumeric character which describe product options.

**Product Options:** This declaration covers all options of the above product which bear the CE Marking.

**Is in conformity with the following standards or other normative documents:**

**Low-Voltage Directive 73/23/EEC:** EN 60950:1992 with Amendments 1, 2, 3, and 4 and with National Deviations.

**EMC Directive 89/336/EEC:** EN 55022:1998, Class A    ITE EMI  
EN 50082-2:1995, Generic industrial immunity

- EN 61000-4-2:1995    Electrostatic discharge
- EN 61000-4-3:1996    Radiated RF EM field
- EN 61000-4-4:1995    Electrical fast transient burst
- EN 61000-4-6:1997    Conducted RF disturbance
- EN 61000-4-8:1993    Power frequency magnetic field

**Supplementary Information:**

The product herewith complies with the requirements of the Low Voltage Directive 73/23/EEC (and amending directive 93/68/EEC), and the EMC Directive 89/336/EEC (and amending directives 91/263/EEC, 92/31/EEC, 93/68/EEC).

The XYCOM Automation model 3515XXXX operator interface workstation was tested for EMC compliance as an apparatus within a system as described in the relevant EMC test files.

Saline, Michigan, USA.

March 3, 2000



**Location**

**Issue  
Date**

**Timothy E. Wallaert  
Vice President, Engineering**

**European Contact:**

Xycom Europe Ltd., 21 Tenter Road, Moulton Park, Northampton, NN3 6AX England  
+44-1604-790-767 (FAX +44-1604-790-722)