

## DECLARATION OF CONFORMITY

**Manufacturers Name:** XYCOM Inc.

**Manufacturers Address:** 750 North Maple Road  
Saline, MI 48176  
U.S.A.

**Declares that the product:**

Product name: Operator Interface Workstation

Model Number: 5200AC

Product Options: This declaration covers all options of the above product.

**Conforms to the following product specifications:**

Safety: EN 60950:A2/08.93

EMC: EN 55022:1994, Class A  
IEC 801-2:1991 /EN 50082-1:1992, 8 kV CD, 15 kV AD  
IEC 801-3:1984 /EN 50082-1:1992, 10 V/m, 27-1000 MHz  
IEC-801-4:1988 /EN 50082-1:1992, 1 kV signal, 2 kV ac

**Supplementary Information:**

The product herewith complies with the requirements of the Low Voltage Directive 73/23/EEC and the EMC Directive 89/336/EEC.

The XYCOM 5200AC operator interface workstation was tested for EMC compliance as a model 5200ACT with the touch screen option installed and as an apparatus within a system as described in the relevant EMC test files.

Saline, Michigan, U.S.A.

3/7/96



**Location**

**Date**

**Anthony Joseph Maresh, Jr.  
Director Product Engineering**

**European Contact:**

Xycom Europe Ltd., 21 Tentor Road, Moulton Park, Northampton, NN3 6AX England  
+44-1604-790-767 (FAX +44-1604-790-722)