

DECLARATION OF CONFORMITY
in accordance with EN 45014:1989

Manufacturers Name: XYCOM Inc.
Manufacturers Address: 750 North Maple Road
Saline, MI 48176
USA.

Declares under our sole responsibility that the product:

Product name: Operator Interface Workstation
Model Number: 9400T
Product Options: This declaration covers all options of the above product which bear the CE Marking.

Is in conformity with the following standards or other normative documents:

- Low-Voltage Directive 73/23/EEC: EN 60950:1992 + A1:1993 + A2 1993
- | | | |
|---------------------------|------------------------|----------------------------------|
| EMC Directive 89/336/EEC: | EN 55022:1994, Class A | ITE EMI |
| | EN 50082-2:1995: | Generic industrial immunity |
| | • EN 61000-4-2:1995 | Electrostatic discharge |
| | • EN 61000-4-3:1996 | Radiated RF EM field |
| | • EN 61000-4-4:1995 | Electrical fast transient burst |
| | • EN 61000-4-8:1993 | Power frequency magnetic field |
| | • ENV 50141:1993 | Conducted RF disturbance |
| | • ENV 50204:1995 | 900 MHz radio telephone immunity |

Supplementary Information:

The product herewith complies with the requirements of the Low Voltage Directive 73/23/EEC and the EMC Directive 89/336/EEC.

The XYCOM model 9400T operator interface workstation was tested for EMC compliance with the Touch Screen option installed and as an apparatus within a system as described in the relevant EMC test files.

| | | |
|------------------------|-------------------|--|
| Saline, Michigan, USA. | 2-Mar-98 |  |
| Location | Issue Date | Anthony Joseph Maresh, Jr. Director Product Engineering |

European Contact:
Xycom Europe Ltd., 21 Tenter Road, Moulton Park, Northampton, NN3 6AX England
+44-1604-790-767 (FAX +44-1604-790-722)