

DECLARATION OF CONFORMITY

in accordance with EN 45014:1989

Manufacturers Name: Xycom Automation Inc.

Manufacturers Address: 750 North Maple Road
Saline, MI 48176
USA.

Declares under our sole responsibility that the product:

Product name: Operator Interface Workstation

Model Number: 9450

Product Options: This declaration covers all options of the above product which bear the CE Marking.

Is in conformity with the following standards or other normative documents:

Low-Voltage Directive 73/23/EEC: EN 60950:1992 with Amendments 1, 2, 3, and 4 and with National Deviations.

EMC Directive 89/336/EEC: EN 55022:1994, Class A ITE EMI
EN 61000-3-2 / 04.95 +A1 / 04.98 + A14 / 10.00, Harmonic Current
EN 61000-3-3 / 01.95, Flicker
EN 50082-2:1995, Generic industrial immunity

- EN 61000-4-2:1995 Electrostatic discharge
- EN 61000-4-3:1996 Radiated RF EM field
- EN 61000-4-4:1995 Electrical fast transient burst
- EN 61000-4-6:1997 Conducted RF disturbance
- EN 61000-4-8:1993 Power frequency magnetic field

Supplementary Information:

The product herewith complies with the requirements of the Low Voltage Directive 73/23/EEC (and amending directive 93/68/EEC), and the EMC Directive 89/336/EEC (and amending directives 91/263/EEC, 92/31/EEC, 93/68/EEC).

The XYCOM model 9450 operator interface workstation was tested for EMC compliance with the Touch Screen option installed and as an apparatus within a system as described in the relevant EMC test files.

Saline, Michigan, USA.

8-Mar-01



Location

Issue

Margaret R. Murdock

Date

Director of Engineering

European Contact:

Xycom Europe Ltd., 21 Tenter Road, Moulton Park, Northampton, NN3 6AX England
+44-1604-790-767 (FAX +44-1604-790-722)